


## DIRECT TAP ON D.I. PIPE



## TAP ON PVC PIPE

NOTF:

NUILE:

1. METER BOX AND SETTER INSTALLED BY DEVELOPER/CONTRACTOR.

2. WATER SERVICE TO BE STUBBED AT CENTER OF LOT.

3. ALL CONNECTIONS SHALL BE MADE USING PACK JOINTS (COMPRESSION) TYPE FITTINGS.

LINDON CITY CORPORATION WATER SERVICE INFORMATION						
SERVICE SIZE	METER BOX SIZE	TYPE OF MATERIAL FOR METER BOX	WATER METER	CONNECTION TYPE	BYPASS	
1"	21" DIA.	CORRUGATED	BY CITY	COMPRESSION	NO	





STATEMENT OF USE					
IS DOCUMENT AND ANY ILLUSTRATIONS HEREON ARE PROVIDED AS STANDARD CONSTRUCTION DETAILS WITHIN					
NDON CITY. DEVIATION FROM THIS DOCUMENT REQUIRES APPROVAL OF LINDON CITY. LINDON CITY CORPORATION					
ID ILLED ENGINEERS CAN NOT BE WELD LIABLE FOR MISLISE OR CHANGES RECARDING THIS DOCUMENT					

AND 3-0-B ENGINEERS CAN NOT BE HELD EINGLE FOR MISUSE OR CHANGES REGARDING THIS DOCUMENT.							
	REVISION						
1	CORRECT PART NUMBER CALLOUT	OMF.	MLC	1/11/04			
2	MODIFIED WATER METER LID PART NUMBER	MLC	MLC	1/11/01			
3	CHANGE TYPE K COPPER LINE TO POLY LINE AND REVISE CALLOUT NOTES	EEA	MLC	6/3/15			
NO.	DESCRIPTION	BY	APR.	DATE			



## TYPICAL CULINARY WATER CONNECTION

STANDARD DRAWING NUMBER:	16
CAD DWG:LC_Sto	Dwgs.dgn
PLOT SCALE:	1.000
DRAWN BY:	BKW
DESIGN BY:	DCT
CHECKED BY:	MIJ
ADOPTED DATE:	
7	JUL 15

LINDON CITY 100 NORTH STATE