


2021 Consumer Confidence

Water Quality Report For Calendar Year 2020

Public Water Supply ID# KS2007906



2601 N Main
PO Box 87
North Newton, KS 67117

Phone: 316-283-7633
Fax: 316-283-6660

nncity@northnewton.org
publicworks@northnewton.org

www.northnewton.org
www.facebook.com/northnewton

April 2021



North Newton is happy to present the annual water quality report. Included in this brochure are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. It is important that customers be aware of the efforts that are made continually to improve their water systems.

IMPORTANT HEALTH INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, those with HIV/AIDS or other system disorders, some elderly, and infants may be particularly at risk of infection. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. Our water is treated according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

The sources of drinking water (tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Your water is treated to remove several contaminants and a disinfectant is added to protect you against microbial contaminants. The Safe Drinking Water Act required states to develop a Source Water Assessment for each public water supply that treats and distributes raw source water in order to identify potential contamination sources.

WATER QUALITY DATA

The tables on the reverse side list all of the drinking water contaminants which were detected during the 2020 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water provided to you is safe.**

QUESTIONS?



Information may be obtained by calling the EPA's Safe Drinking Water Hotline: 800-426-4791. Additional information is located at these websites: www.epa.gov/watrhome and www.cdc.gov.

To learn more about our local drinking water, you are invited to attend any North Newton City Council meeting and ask questions. These are held the second Monday of each month at 7:00 P.M. in City Hall, or you may contact the City Administrator at 316-283-7633.

Testing results for the CITY OF NORTH NEWTON

Your water is a blend of groundwater from four wells owned by North Newton and is treated at our own treatment facility. The following tables list all of the drinking water contaminants detected during the mandated monitoring periods. Because of sampling schedules, some results may be older than one year.

Disinfection Byproducts—2020	Highest Running Annual Avg	Range	MCL	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	6 ppb	5.7	60	By-product of drinking water disinfection
TOTAL TRIHALOMETHANES (TTHMs)	16 ppb	16	80	By-product of drinking water chlorination

Metal	Period	90th Percentile	Range	AL	Sites over AL	Below EPA Limits?	Typical Source
COPPER	2016-18	0.97 ppm	0.28 -1.2	1.3	0	Yes	Corrosion of household plumbing
LEAD	2016-18	1.6 ppb	0 -1.8	15	0	Yes	Corrosion of household plumbing

Regulated Contaminants- Collection Date	Highest Value	Range	MCL	Below EPA Limits?	Typical Source
ARSENIC—3/4/2019	4.2 ppb	4.2	10	Yes	Erosion of natural deposits
ATRAZINE—1/7/2019	0.04 ppb	0.04	3	Yes	Runoff from row crop herbicides
BARIUM—3/4/2019	0.22 ppm	0.22	2	Yes	Discharge from metal refineries
CHROMIUM—3/4/2019	1.6 ppb	1.6	100	Yes	Discharge from steel & pulp mills
FLUORIDE—4/22/2020	.4 ppm	0.18 - 0.4	4	Yes	Erosion of natural deposits; water additive
NITRATE—1/13/2020	8 ppm	8	10	Yes	Runoff from fertilizer use
SELENIUM—3/4/2019	4.3 ppb	4.3	50	Yes	Erosion of natural deposits

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

If present, elevated levels of **lead** can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. When your water has been sitting for several hours, minimize the lead exposure risk by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, have your water tested. For more information you may call the Safe Drinking Water Hotline or go to <http://www.epa.gov/safewater/lead>.

Secondary Contaminants—No Federal Max. Contaminant Level Collection Date 3/4/19	Highest Value	SMCL
ALKALINITY, TOTAL	230 mg/L	300
CALCIUM	76 mg/L	200
CHLORIDE	25 mg/L	250
CONDUCTIVITY @ 25 C UMHOS/CM	660 umhos/cm	1500
HARDNESS, TOTAL (AS CaCO3)	250 mg/L	400
MAGNESIUM	15 mg/L	150
PH	7.3 PH	8.5
PHOSPHORUS, TOTAL	0.58 mg/L	5
POTASSIUM	1.6 mg/L	100
SILICA	29 mg/L	50
SODIUM	42 mg/L	100
SULFATE	34 mg/L	250
TOTAL DISSOLVED SOLIDS	390 mg/L	500
ZINC	0.014 mg/L	5

Chlorine/Chloramines Max. Disinfection Level	Monitoring Period Average	Running Annual Average
8/1/2020—8/31/2020	0.8 mg/L	0.8 mg/L

TERMS & ABBREVIATIONS

AL (Action Level): the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the goal as feasible using the best available treatment technology.

ppb: parts per billion or micrograms per liter (µg/L)

ppm: parts per million or milligrams per liter (mg/L)

Running Annual Average: an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

SMCL (Secondary Maximum Contaminant Level): recommended level for a contaminant that is not regulated and has no MCL.

UMHOS/CM: electrical conductivity measures the rate at which a small electrical current flows through a solution, usually measured in micromhos per centimeter.

90th Percentile: Value is calculated by first putting all samples in order from lowest to highest and numbering them. Multiply number of samples by .09. The sample result with the number corresponding to this calculation is the 90th percentile.

What makes water hard? If substantial amounts of either calcium or magnesium, both nontoxic minerals, are present in drinking water, the water is said to be hard. Hard water does not dissolve soap readily, so making lather for washing and cleaning is difficult. Conversely, water containing little calcium or magnesium is called soft water.

POSSIBLE CONTAMINANTS IN SOURCE WATER BEFORE TREATMENT:

Microbial contaminants—such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants—such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides—may come from a variety of sources such as storm water runoff, agriculture and residential users.

Radioactive contaminants—can be naturally occurring or the result of mining activity.

Organic contaminants—including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can come from gas stations, urban storm water runoff, and septic systems.

It is a fact that bacteria and other microorganisms inhabit our world. They can be found in our food, on our skin, in our bodies, and in the air, soil and water. Some are harmful and some are not. **Coliform bacteria** are common in the environment and are generally not harmful themselves. The presence of this bacterial form in drinking water is a concern because it indicates that the water may be contaminated with disease-causing organisms. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, we will notify the public.

Our water system tested a minimum of two samples per month in accordance with the Total Coliform Rule for microbiological contaminants. There were no Total Coliform Bacteria violations during the 2020 calendar year.