



CABIN/CONDO FIRE INSPECTION GUIDELINES

The following items are required to be corrected/installed prior to a business license inspection by the Fire Department.

1. A minimum class 2A:10BC fire extinguisher shall be located in a conspicuous location where it will be readily accessible and immediately available for use. All fire extinguishers are required to be serviced and tagged by a licensed contractor.
2. Smoke Detectors are required to be in working condition and are to be located in all sleeping rooms and hallways leading to the sleeping rooms.
3. All electrical outlets, light switches, junction boxes and other related electrical wiring must have all cover plates on and be in good working condition.
4. All electrical circuit breakers are required to be labeled in a manner that will indicate where and what the breaker serves.
5. The home's address must be placed on the building in such a position as to be plainly visible and legible from the street or road fronting the property. Lettering is to be a minimum of four inches (4") in height.
6. Storage of combustible or flammable items is not allowed in furnace rooms, mechanical rooms or electrical rooms.
7. A maximum occupancy sign identifying total number of persons allowed will be posted near the front entry way and visible at all times.

Business Name: _____ **Owner** _____ **Phone:** _____
Address to be inspected: _____ **Inspection Date:** _____

Required Items	Comments	In Compliance	Re-inspection Required
#1			
#2			
#3			
#4			
#5			
#6			
#7			

Brian Head Fire Department _____ Date _____
 Signature

Re-Inspection Date: _____ Items Corrected: _____

Brian Head Fire Dept. Signed Off: _____ Date: _____
 Signature