



ORDINANCE NO. 18-013

AN ORDINANCE AMENDING THE BRIAN HEAD STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION MANUAL, CHAPTER 5, SANITARY SEWER, STORM DRAIN LINES AND LATERALS, SECTION 3 FIELD TESTING; AND PROVIDING FOR AN EFFECTIVE DATE.

WHEREAS, the Brian Head Town Council adopted Ordinance No. 07-011 establishing the Brian Head Standard Specifications for Public Works Construction Manual Public Works Standards for Construction on September 11, 2007 which established certain standards for plans and specifications for construction within the Town boundaries; and

WHEREAS, The Brian Head Public Works Director has determined an amendment to the Public Works Standards to ensure they are up to date with industry and engineering standards, and;

WHEREAS, the Brian Head Town Council has determined that it is in the best interest of the public health, safety, and welfare of Brian Head Town that the Standard Specifications for Public Works Construction Manual be amended.

NOW THEREFORE, BE IT ORDAINED BY THE BRIAN HEAD TOWN COUNCIL OF IRON COUNTY, UTAH AS FOLLOWS:

SECTION 1. The Brian Head Town Standard Specifications for Public Works Construction be amended as follows for Chapter 5, Sanitary Sewer, Storm Drains and Laterals, Section 5 Field Tests is hereby amended as follows:

Chapter 5 – Sanitary Sewer, Storm Drain Lines and Laterals

5.3 Field Testing

5.3.2 PVC Deflection Test. *All sewer pipe six inches (6") or larger shall be tested for deflection with a mandrel. The mandrel shall be a rigid device sized to pass through a pipe having five percent (5%) or less deflection. These allowances shall include deformations due to all causes (wall thickness variations, shipping, production, backfill, heat, etc). The mandrel device shall be cylindrical in shape and shall comply with the manufacturer's recommendations.*

The mandrel shall be hand pulled through all sewer line mains, lateral sewer lines shall not subject to this requirement. Any sections of sewer not passing the mandrel shall be uncovered and repaired by the Contractor. The Contractor shall re-round or replace the sewer to the satisfaction of the Town's Representative. All repaired sections shall be re-tested as noted above.

Deflection tests shall be conducted only after the final trench backfill is placed to final grade and compacted.

5.3.3 Camera/Electronic Media Testing: *The Contractor or his representative (a qualified firm or individual agreed upon by the Public Works Director and the Contractor) shall furnish labor,*

equipment, and materials, including camera and electronic media formats, and shall perform, in the presence of a Town Representative, an internal camera test of the completed pipe before it can be placed in service. The contractor shall supply the Town with a copy of the electronic record. The test shall be subject to the Public Works Director's approval. Any defects in the pipe or the pipe installation noted on the internal camera inspection shall be corrected by the contractor and the repaired section shall be camera inspected after the repair to verify that the defective section has been corrected. Camera Testing shall be identified in any bid document that is prepared for or by Brian Head Town as a requirement of the Town.

SECTION 2. Effective Date. Upon this Ordinance being adopted by the Brian Head Town Council of Iron County, Utah, all provisions of this ordinance shall be incorporated. All provisions of the Brian Head Public Works Standards for Construction Manual that are inconsistent with the express terms of this ordinance shall be repealed. All other provisions of the Brian Head Public Works Standards for Construction Manual shall remain in full force.

SECTION 3. Conflict. To the extent of any conflict between other Town, County, State, or Federal ordinances or regulations, and this ordinance, the more restrictive is deemed to be controlling.

SECTION 4. Severability Clause. If any section, subsection, sentence, clause, phrase, or portion of this ordinance is for any reason, held invalid or unconstitutional by any court or competent jurisdiction, such portions shall be deemed a separate, distinct and independent provision, and such holding shall not affect the validity of the remaining portions of this ordinance.

PASSED AND ADOPTED BY THE BRIAN HEAD TOWN COUNCIL OF IRON COUNTY, UTAH this 22nd day of October 2018, with the following vote.


Vote:

| | |
|-------------------------------|-----|
| Mayor Clayton Calloway | Aye |
| Council Member Larry Freeberg | Aye |
| Council Member Lynn Mulder | Aye |
| Council Member Shad Hunter | Aye |
| Council Member Kelly Marshall | Aye |

BRIAN HEAD TOWN

By: 
Clayton Calloway, Mayor


ATTEST:


Nancy Leigh, Town Clerk



CERTIFICATE OF PASSAGE AND POSTING

I hereby certify that the above Ordinance is a true and accurate copy, including all attachments, of the Ordinance passed by the Town Council on the 22nd day of October 2018, and have posted a complete copy of the ordinance in three conspicuous places within the Town of Brian Head, to-wit: Town Hall, Post Office and the Mail.


Nancy Leigh, Town Clerk