



**NOTES:**

1. ALL MAIN LINE PIPE AND FITTINGS SHALL BE DUCTILE IRON.
2. PORTLAND CEMENT CONCRETE MAY ONLY BE POURED ON UNDISTURBED SOIL, 3/4" CRUSHED GRAVEL, OR COMPACTED UNTREATED BASE COURSE.
3. METER VAULTS SHALL BE PLACED IN LANDSCAPE AREAS WHENEVER POSSIBLE.