

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Uintah City has a Corrective Action rating with the State of Utah Division of Drinking Water

Our water system is generally in non-compliance due to physical deficiencies resulting in a Corrective Action rating with the Utah Division of Drinking Water. The Utah Division of Drinking Water maintains ratings for all public water systems. An Approved rating shows that a public water system is generally in compliance with all rules and regulations to maintain safe drinking water. A Corrective Action rating shows a water system is generally in non-compliance through physical facility deficiencies, however that the water system is taking appropriate actions to return to compliance and an Approved status.

Although this is not an emergency, as our customers, you have a right to know the rating of your public water system, and what we are doing to correct this situation. The following table shows the specific issues within our system:

List outstanding Deficiencies and the plan for returning to an Approved rating.

Deficiency/Violation	Date of Occurrence	Plan to return to compliance	Severity (deficiencies: significant, minor, recommended, violations: major, minor)
Bybee Tank Storage Facility shows evidence of leakage.	10/31/2018	Concrete sealant XYPEX will be applied to affected area when weather permits.	Significant

What should I do?

You do not need to use an alternative (e.g., bottled) water supply.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately.

What happened? What is being done?

We will apply a concrete sealant XYPEX to the affected area as soon as weather permits. We anticipate resolving the problem by July 1st, 2019.

For more information, please contact Council member Kristi Bell at 435-757-2444 or 2191 E 6550 S Uintah, UT 84405.